## **NOTICE**

## NOTICE OF PROPOSED CORRECTIVE ACTION

Section 280.67 of the S.C. Underground Storage Tank Control Regulations (R.61-92) requires that any Corrective Action Plan prepared to meet the requirements of 280.66 must be placed on notice for public comment. The following applicant has submitted a Corrective Action Plan for the rehabilitation of ground water contaminated by petroleum constituents released from underground storage tanks.

Applicant: H & S Petroleum, PO Box 266, Summerton, SC 29148. The E P Johnson Grocery formerly operated two underground storage tanks (UST) used for storage of petroleum. The USTs were removed from the ground in April 1992. The facility is located at 6342 Old State Road near Holly Hill in Orangeburg County, South Carolina.

Corrective action will consist of the extraction of fluids using high vacuum pressure followed by the injection of hydrogen peroxide and iron sulfate to stimulate chemical reduction followed by the injection of micro-organisms and nutrients to enhance bioremediation followed by natural attenuation.

A copy of the Corrective Action Plan is available for review at the Freedom of Information Office (803-898-3880) SCDHEC 2600 Bull Street in Columbia, SC.

Persons wishing to comment upon or object to Corrective Action approval are invited to submit same in writing on or before October 8, 2004 to South Carolina Department of Health and Environmental Control, Underground Storage Tank Program, 2600 Bull Street, Columbia, S.C. 29201 or call Read Miner at (800) 826-5435. The public notice # should be placed at the top of the first page of comments. Where there is a significant degree of public interest, the SCDHEC will hold a public hearing.

Please bring the foregoing to the attention of persons who you know will be interested in this matter.